

**MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT, CENTRAL ZONE
SHIV MANDIR MARG, LAJPAT NAGAR, NEW DELHI**

No.DHO/CNZ/2025/D 1515

Dated: 20/11/2025

HEALTH CERTIFICATE

The school premises were re- inspected by officials of the Public Health Department in the presence of school management, and found to be in sanitary and hygienic condition from a health point of view. The details are as follow:

Name of the school: M/s ST.PAUL' S DIOCESAN School.

Address of School: JANGPURA , New Delhi-110014

Shifts: One Timing: MORNING

No. of Students : Boys:197 Girls:136 Total:-333

No. of Staff (Teachers) : Female: 26 Male: 01 Total: 27

That the accommodation provided for the class rooms as calculated.

1. (A) On floor space is sufficient Yes
(B) On Cubic space is sufficient Yes
2. That the classrooms are well ventilated Yes
3. That the classrooms are kept neat and clean Yes
4. That the classrooms are well lighted Yes
5. That the drinking water is wholesome Wholesome
6. That the latrines arrangement is adequate and there are sufficient latrines.
7. That urinals arrangement is adequate and there are sufficient urinals

This certificate is issued for sanitary and hygienic conditions from the health point of view of the school premises. This certificate has no bearing structure stability/ unauthorized construction and fire safety.



Dy. Health Officer
Central Zone

Deputy Health Officer
Central Zone, MCD

"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL ZONAL LABORATORY (SOUTH)
WATER WORKS OKHLA DELHI-110025



Licence No- CRO/QM/L-8004290 IS/ISO 9001:2015

BACTERIOLOGICAL ANALYSIS REPORT

Dated: 04.08.2025

No. DJB/DTQC/ CWA (W&S)III /ACWA (south)/ Bact/P.S./2025-2026/94-95/01.8.2025

Bacteriological Analysis Report as per IS 10500:2012

To M/S – St. Paul's Diocesan School Jangpura New Delhi -110025	Party Ref.No./Date: spds/0725/JB01/24.07.2025 Dept. Challan No. /date: 41/25.07.2025 Dt.of sample collection: 01.08.2025 No. of Sample: Two (02) Collected by: Name- Mrs. Shweta Kirad Desig. - Asst. Bacteriologist
-------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

S.No.	Particulars	Clarity	Residual chlorine	Total Coliform Count/ 100 ml sample
1.	Direct Supply point near Canteen	Clear	0.20	0
2.	RO Drinking Point at 2 nd floor	Clear	Nil	0

RESULT: -Collected water samples as mentioned above at S.No. 1&2 were found bacteriological satisfactory; hence the water/sources are fit for drinking/recreational purpose subject to satisfactory attached Physical-Chemical Analysis report also.

04/08/25
ACWA (SOUTH ZONE)

Dr. D. P. SINGH
ACWA (SOUTH ZONE)
Delhi Jal Board
Govt. of NCT of Delhi

04/08/25
BACTERIOLOGIST (SOUTH ZONE)
MANESHWAR DIXIT
BACTERIOLOGIST (SOUTH ZONE)
Delhi Jal Board
Govt. of NCT of Delhi

04/08/25
ASST./BACT.



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL ZONAL LABORATORY (SOUTH)
WATER WORKS OKHLA DELHI-110025



Licence No- CRO/QM/L-8004290 IS/ISO 9001:2015

A.C.W.A.(South)/Paid/2025-26/P64-65 Challan No.41 Dated 25.07.2025

Serial No.8185

Date-04.08.2025

St. Paul's Diocesan School

Jasola

New Delhi-110025

Date of sample collection : 30.07.2025

S.No	Characteristics	Unit	Acceptable Limit	Point near Water Meter (SNo 01)	Drinking Point near Room No 1 (SNo-2)
1.	Clarity	Unit	5	Clear	Clear
2.	Odour	---	Agreeable	No. Obj.	No. Obj.
3.	pH Value	---	6.5-8.5	7.5	6.8
4.	Turbidity	NTU	1	2.18	0.77
5.	Conductivity	µmho/cm ²	---	201	131
6.	Total Dissolved Solids	mg/L	500	131	85
7.	Phenolphthalein Alkalinity	mg/L	----	NIL	NIL
8.	Total Alkalinity (as CaCO ₃)	mg/L	200	62	36
9.	Total Hardness (as CaCO ₃)	mg/L	200	100	36
10.	Carbonate hardness	mg/L	----	62	36
11.	Non- Carbonate Hardness	mg/L	----	38	Nil
12.	Calcium Hardness	mg/L	----	62	08
13.	Magnesium Hardness	mg/L	----	38	28
14.	Chloride (as Cl)	mg/L	250	14	10
15.	Ammonia (as Total N)	mg/L	0.5	ND	ND
16.	Nitrite (as N)	mg/L	----	ND	ND
17.	Nitrate	Mg/L	45	2.1	1.4
18.	Sulphate (as SO ₄)	mg/L	200	06	04
19.	Fluoride	mg/L	1.0	0.37	0.22
20.	Iron	Mg/l	0.3	0.04	0.02
21.	Calcium (as Ca)	mg/L	75	24.8	3.2
22.	Magnesium (as Mg)	mg/L	30	9.12	6.72
23.	Free Residual Chlorine	mg/L	0.2	0.20	Nil

[Signature]
ACWA (SOUTH)



[Signature]
CHEMIST
RITU GROVER
CHEMIST (SOUTH ZONE)
Delhi Jal Board
Govt. of NCT of Delhi

[Signature]
04/08/2025

A/CHEMIST



Dr. D. P. SINGH
ACWA (SOUTH ZONE)
Delhi Jal Board
Govt. of NCT of Delhi